

ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿರ್ಮಿತ

BANGALORE ELECTRICITY SUPPLY COMPANY LTD

E1 PILLANNA GARDEN

Receipt Number 983981595622
Reciept Date 17-06-2021 12:54:

87

Cash Counter BESCOM - E1-SDO C
ash Counter

Payor Account ID 9839815698
SUSPENSE & NON-REVE

HUE

SK Person Name ACCOUNT : BENGALURU
E1 SUB- HEIGHT DEVELOPERS

DIVISION

RR Number 3
Total Payment Rs5,900.00
(Including GST, If Applicable)
Mode of pay Cash
Purpose Non Revenue
Non Revenue category HISC
Five Thousand Nine Hundred Rupees

nly

THANK YOU



ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿಯಮಿತ

(ಕರ್ನಾಟಕ ಸರ್ಕಾರದ ಸಂಪೂರ್ಣ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ)

No.EE/SND/AEE(O)/2021-22/1405-406

Office of the:

Executive Engineer, Ele.,
C, O & M, Shivajinagar Dvn,
Nandidurga Road, BESCOM,
Bangalore - 560 046.

eeadnleast.work@gmail.com

Date: 04 JUL 2021

To

M/s. Sky Height Developers,
No 41, Nagawara Main Road ,
KG Halli, Bangalore-560045

Sir,

Sub: Issue of NOC to the proposed Residential building for Arranging
LT Power Supply to an extent of 373 KW infavour of
M/s. Sky Height Developers, No 41, Nagawara Main Road , KG
Halli, Bangalore - Reg

Ref: Asst. Executive Engineer, Ele., E1 Sub Division, Office letter
No. 418; dtd: 25.06.2021

Anent to above, "No Objection Certificate" from Shivajinagara Division,
BESCOM, is hereby issued for Arranging LT Power Supply to an extent of 373
KW infavour of M/s. Sky Height Developers, No 41, Nagawara Main Road , KG
Halli, Bangalore., Subject to the following conditions:-

- 1 Power Supply to your proposed Residential/Commercial building will
be arranged with the following arrangements upto your premises.

REGULAR SOURCE:-


- It is Proposed 11KV New feeder from of 66/11KV HBR Muss by
using 3X400Sqmm HT UG cable for distance of 3KM.

ALTERNATE SOURCE:-

- It is Proposed to tap 11KV Power supply from F15 feeder of
66/11KV PR Muss line using XLPE 3X400Sqmm HT UG cable for
distance of 2.5KM.

- 2 You have to develop the Infrastructure including the cost of 11 KV lines etc., as mentioned above on Self Execution basis through a licenced Class-I electrical contractor by paying necessary supervision charges to BESCOM duly observing BESCOM formalities.
- 3 If any existing KPTCL/BESCOM lines which are passing through the proposed building premises shall be shifted at your cost duly availing the permissions from concerned authorities. This NOC does not apply to the premises where EHT lines are passing through the premises for which NOC is to be obtained from the concerned authorities.
- 4 If any installation existing the same shall be surrendered by clearing all arrears before taking up infrastructure work in the premises.
- 5 While applying for power supply to the said Building at the above address. You shall observe all rules as per KERC Electricity Supply and Distribution code.
- 6 Power Supply shall be arranged to the said Building based on the provisions of regulations of BESCOM is applicable at that time.
- 7 This "NOC" is issued only for the purpose of obtaining sanction plan for "Building" from BDA/BBMP/Competent authorities and is not a commitment for power sanction from BESCOM. Power Supply will be sanctioned when applied for, subject to feasibility at that time.
- 8 The approximate load requirement of the above Building is 373 KW.
- 9 This NOC is valid for a period of Two year from the date of issue.
- 10 The NOC processing fee Rs. 5,900/- collected, vide Rt. No. 983981595622; dtd. 17.06.2021.

Yours faithfully,


(Yogesh K)
Executive Engineer, Ele.,
Shivajinagara Division,
BESCOM, Bangalore.

Copy to the Asst. Executive Engineer, Ele., E9 Sub Division, BESCOM, outer ring road, Nagawara, Bangalore, for information.